

FIRE SAFETY – UNDERTAKING

I, SIMADRI DEBBARMA, Principal of MOHANPUR GIRLS' H.S. SCHOOL bearing online registration no. Do hereby undertake that the school run/applied under regular category is unable to obtain / renew Fire Safety Certificate issued from the Fire Safety Department of the State Govt. / Competent Govt. Authority e.g. Municipal Corporation etc. of the concerned area till date of application. The School was last inspected for the fire safety on 10/04/2026.

I assure that before starting of the regular school / commencement of session the above safety certificate will be obtained and submitted. In the meanwhile whole responsibility of the safety and security of staff and students will be on undersigned. Therefore, being a regular category school it may be provincially allowed.

(Principal Signature) *Simadri Debarma*

(Principal Name): SIMADRI DEBBARMA

(School Address): West Taranagar, Sidhai Mohanpur, West Tripura, Pin-799211

Date: 21/05/2026

Place: MOHANPUR

Seal:

SD
21/05/26

(SIMADRI DEBBARMA)
Vice-Principal
Mohanpur Girls' H.S. School.
Mohanpur, Tripura (W).



GOVERNMENT OF TRIPURA
DIRECTORATE OF FIRE & EMERGENCY
SERVICES
AGARTALA : TRIPURA



Phone: 0381-232-6451

Email: dg.fire-tr@gov.in

website: www.fireservice.tripura.gov.in

No: FSRTFES/2025/00222

Dated: 12/03/2026

To,
Simadri Debbarma
Mohanpur, West Tripura
Mohanpur S.O - 799211

Sub: **Fire Safety Recommendation** For Application Reference No **FSRTFES/2025/00222** .

With reference to your Application Reference No FSRTFES/2025/00222 Dated 07/02/2026 Fire Safety Recommendation on fire prevention and fire safety measures of the following building/premises is hereby issued in accordance with the conditions laid down in the relevant portions of Part-IV of the latest National Building Code and the Tripura Building Rules.

Name of the Applicant:	Simadri Debbarma			
Name of Owner with Plot details:	S. No.	Owner Name and Address		
	1.	দং ত্রিপুরা সরকারের পক্ষে শিক্ষা বিভাগ কর্তৃক রক্ষিত - - -		
	S. No.	Plot No	Total Area	Classification
	1.	1601	0.8	----
	2.	1602	0.14	টিলা
	3.	2395	1	----
	4.	3399	0.8	----
	5.	3400	0.49	----
	6.	4072	0.1	----
	7.	4073	1.02	টিলা
8.	4082	0.89	টিলা	
9.	4141	1.97	----	
Name of the Property/ Organization/ Commercial establishment	Mohanpur Girls' H.S. School			
Address of the Building/ Premises:	Area Name Taranagar, Ward No.5, Mohanpur Municipal Council, Post Office Mohanpur S.O - 799211, West Tripura District, Tripura.			

A Fire Safety Certificate (FSC) will be issued, subject to verification of compliance of fire prevention and fire safety measures on which the fire safety recommendations enumerated in the attached letter and further submission of application through online system.

Director,

Fire & Emergency Services,
Or Authorized Signatory
Tripura : Agartala

***** WE SERVE TO SAVE*****

This certificate shall not be used by the Insurance service provider

Fire Safety Advisory and Suggestion:

- 1.Road Width- 6mtr.(Exist).
- 2.Gate Width is 6mtr.(Exist).
- 3.Staircase required 2 meter.
- 4 Staircase upper floors required 2 meter.
- 5 Corridor required 2 meter
- 6.Door size is 1 meter for all building
- 7 1(one) No Co2 fire extinguisher having a capacity of 4.5kg to be installed near the electric panel board , 1(One) No's Co2 fire extinguisher having a capacity of 2kg to be installed in the Ground Floor to 2nd floor after 15 meter distance interval each floor.
- 8.1(One) No's ABC fire extinguisher having a capacity of 6kg to be installed in the Ground Floor to 2nd floor after 15 meter distance interval each floor.
- 9.1(one) No DCP fire extinguisher having a capacity of 6kg to be installed in the Ground Floor to 2nd floor after 15 meter distance interval each floor
- 11.Hose reel length 30 meters
- 12.Hose reel nozzle diameter 19mm
- 13.Alternate power supply should be provided.
- 14.Hooter with battery backup to be installed in the premises.
- 15.Manually operated electronic fire alarm Manual call point with battery backup to be installed in the premises.
- 16.Down comer system to be installed the building with mild steel pipe dia not less then 100mm/04 inch in diameter and 4.5mm in thickness B- class 02 way inlet valve to be provided at front side of the building and connected with the down comer system.
- 17.01(one) landing valve to be provided at the hose reel point .
- 18.01(one) double door hose box along with one short branch, two delivery hose & fireman axe to be installed near each hose reel point.
- 19.01(one) terrace level fire pump happng a discharge capacity of 450 LPM with a minimum pressure of 3.5kg/cm2 to be installed in the building.
- 20.Terrace level head of pumps to be 50m.
- 21.Terrace level power supply should be in three phases.
- 22.Auto pump controller to be installed in the terrace level pump along with an Air release valve , pressure gauge & pressure switch to be provided at the terrace level of the building.
- 22.Auto pump controller to be installed in the terrace level pump along with an Air release valve , pressure gauge & pressure switch to be provided at the terrace level of the building.
- 23.Terrace tank capacity of 10,000 liters to be constructed in the building exclusively for firefighting purpose.
- 24.Exit/Entry to be provided in all building.
- 25.Stand by power supply should be provided.
- 26.Trained fire fighter should be appointed to operated the fire fighting equipment's in case of any emergency.
- 27.Electric diagram showing separate circuits of fire safety measures diagram will be used to verify. Relevant compliance with the national building code is 1646 & for functional test of fire safety related equipment the electric contractor will sign a certificate of compliance with electric rules and the diagram which is to be submitted/upload at the time of applying NOC online.

NB:-Issued

Digitally signed by MEGHA JAIN
Date:12-03-2026 16:58:23 PM